



enclosure for command devices, 22 mm, round, enclosure material plastic, enclosure top part gray, 3 control points plastic, C=Pushbutton green, label: Up, 1 NO, 1 NC, screw terminal, B=Pushbutton black, label: Down, 1 NO, 1 NC, screw terminal, A=Pushbutton red, label: Stop, 1 NO, 1 NC, screw terminal, floor mounting, 1xM20 each on top and bottom, Labels glued in

<b>product brand name</b>	SIRIUS ACT
<b>product designation</b>	Enclosures
<b>product type designation</b>	3SU1
<b>equipment of commanding and signaling device</b>	A = Pushbutton / B = Pushbutton / C = Pushbutton
<b>manufacturer's article number</b>	
<ul style="list-style-type: none"> <li>of supplied contact module</li> </ul>	<p>A1 = 3SU1400-2AA10-1BA0 / A2 = 3SU1400-2AA10-1CA0 / B1 = 3SU1400-2AA10-1BA0 / B2 = 3SU1400-2AA10-1CA0 / C1 = 3SU1400-2AA10-1BA0 / C2 = 3SU1400-2AA10-1CA0</p> <p><a href="#">3SU1400-2AA10-1BA0</a></p>
<ul style="list-style-type: none"> <li>of supplied contact module at the command point A 1</li> </ul>	<a href="#">3SU1400-2AA10-1CA0</a>
<ul style="list-style-type: none"> <li>of supplied contact module at the command point A 2</li> </ul>	<a href="#">3SU1400-2AA10-1BA0</a>
<ul style="list-style-type: none"> <li>of supplied contact module at the command point B 1</li> </ul>	<a href="#">3SU1400-2AA10-1CA0</a>
<ul style="list-style-type: none"> <li>of supplied contact module at the command point B 2</li> </ul>	<a href="#">3SU1400-2AA10-1BA0</a>
<ul style="list-style-type: none"> <li>of supplied contact module at the command point C 1</li> </ul>	<a href="#">3SU1400-2AA10-1CA0</a>
<ul style="list-style-type: none"> <li>of supplied contact module at the command point C 2</li> </ul>	<a href="#">3SU1400-2AA10-1CA0</a>
<ul style="list-style-type: none"> <li>of the supplied holder</li> </ul>	<p>A = 3SU1500-0AA10-0AA0, B = 3SU1500-0AA10-0AA0, C = 3SU1500-0AA10-0AA0</p> <p><a href="#">3SU1500-0AA10-0AA0</a></p> <p><a href="#">3SU1500-0AA10-0AA0</a></p> <p><a href="#">3SU1500-0AA10-0AA0</a></p>
<ul style="list-style-type: none"> <li>of the supplied holder at the command point A</li> </ul>	<a href="#">3SU1500-0AA10-0AA0</a>
<ul style="list-style-type: none"> <li>of the supplied holder at the command point B</li> </ul>	<a href="#">3SU1500-0AA10-0AA0</a>
<ul style="list-style-type: none"> <li>of the supplied holder at the command point C</li> </ul>	<a href="#">3SU1500-0AA10-0AA0</a>
<ul style="list-style-type: none"> <li>of the supplied actuator</li> </ul>	<p>A = 3SU1000-0AB20-0AA0 / B = 3SU1000-0AB10-0AA0 / C = 3SU1000-0AB40-0AA0</p> <p><a href="#">3SU1000-0AB20-0AA0</a></p> <p><a href="#">3SU1000-0AB10-0AA0</a></p> <p><a href="#">3SU1000-0AB40-0AA0</a></p>
<ul style="list-style-type: none"> <li>of the supplied actuator at the command point A</li> </ul>	<a href="#">3SU1000-0AB20-0AA0</a>
<ul style="list-style-type: none"> <li>of the supplied actuator at the command point B</li> </ul>	<a href="#">3SU1000-0AB10-0AA0</a>
<ul style="list-style-type: none"> <li>of the supplied actuator at the command point C</li> </ul>	<a href="#">3SU1000-0AB40-0AA0</a>
<ul style="list-style-type: none"> <li>of supplied empty enclosure</li> </ul>	<a href="#">3SU1803-0AZ00 KOY</a>
<ul style="list-style-type: none"> <li>of supplied accessory</li> </ul>	<p>A = 3SU1900-0AF16-0DS0, B = 3SU1900-0AF16-0DM0, C = 3SU1900-0AF16-0DL0</p> <p><a href="#">3SU1900-0AF16-0DS0</a></p> <p><a href="#">3SU1900-0AF16-0DM0</a></p> <p><a href="#">3SU1900-0AF16-0DL0</a></p>
<ul style="list-style-type: none"> <li>of the supplied accessories at the command point A</li> </ul>	<a href="#">3SU1900-0AF16-0DS0</a>
<ul style="list-style-type: none"> <li>of the supplied accessories at the command point B</li> </ul>	<a href="#">3SU1900-0AF16-0DM0</a>
<ul style="list-style-type: none"> <li>of the supplied accessories at the command point C</li> </ul>	<a href="#">3SU1900-0AF16-0DL0</a>
<b>Enclosure</b>	
<b>design of the housing</b>	with recess for label
<b>shape of the enclosure front</b>	rectangular
<b>material of the enclosure</b>	plastic
<b>number of command points</b>	3
<b>product component</b>	

<ul style="list-style-type: none"> <li>• EMERGENCY STOP device</li> </ul>	No
<ul style="list-style-type: none"> <li>• protective collar</li> </ul>	No
color of the enclosure top part	grey
<b>delivery state</b>	
<ul style="list-style-type: none"> <li>• as a kit</li> </ul>	No
<ul style="list-style-type: none"> <li>• pre-wired on strip terminal</li> </ul>	No
<b>fastening method of the enclosure</b>	Vertical
<b>Actuator</b>	
<b>design of the actuating element</b>	Pushbutton / pushbutton / pushbutton
suitability for use EMERGENCY OFF switch	No
product feature lockout	No
product extension optional light source	No
color of the actuating element	A = red / B = black / C = green
<b>material of the actuating element</b>	plastic
<b>shape of the actuating element</b>	round
<b>number of contact modules</b>	6
<b>type of unlocking device</b>	A = none / B = none / C = none
<b>Front ring</b>	
<b>product component front ring</b>	Yes
<b>design of the front ring</b>	Standard
<b>material of the front ring</b>	plastic
<b>color of the front ring</b>	black
<b>Holder</b>	
<b>material of the holder</b>	Plastic
<b>Display</b>	
<b>number of LED modules</b>	0
<b>General technical data</b>	
<b>product function</b>	
<ul style="list-style-type: none"> <li>• positive opening</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• EMERGENCY OFF function</li> </ul>	No
<ul style="list-style-type: none"> <li>• EMERGENCY STOP function</li> </ul>	No
<b>protection class IP</b>	IP66, IP67, IP69(IP69K)
<b>degree of protection NEMA rating</b>	1, 2, 3, 3R, 4, 4X, 12K, 13
<b>shock resistance</b>	
<ul style="list-style-type: none"> <li>• according to IEC 60068-2-27</li> </ul>	sinusoidal half-wave 15g / 11 ms
<ul style="list-style-type: none"> <li>• for railway applications according to EN 61373</li> </ul>	Category 1, Class B
<b>vibration resistance</b>	
<ul style="list-style-type: none"> <li>• according to IEC 60068-2-6</li> </ul>	10 ... 500 Hz: 5g
<ul style="list-style-type: none"> <li>• for railway applications according to EN 61373</li> </ul>	Category 1, Class B
<b>reference code according to IEC 81346-2</b>	S
<b>continuous current of the C characteristic MCB</b>	10 A; for a short-circuit current smaller than 400 A
<b>continuous current of the quick DIAZED fuse link</b>	10 A
<b>continuous current of the DIAZED fuse link gG</b>	10 A
<b>Substance Prohibitance (Date)</b>	10/01/2014
<b>operating voltage</b>	
<ul style="list-style-type: none"> <li>• at AC <ul style="list-style-type: none"> <li>— at 50 Hz rated value</li> <li>— at 60 Hz rated value</li> </ul> </li> </ul>	5 ... 500 V
<ul style="list-style-type: none"> <li>• at DC rated value</li> </ul>	5 ... 500 V
<b>Communication/ Protocol</b>	
design of the interface for communication	without
<b>Auxiliary circuit</b>	
<b>design of the contact of auxiliary contacts</b>	Silver alloy
<b>number of NC contacts for auxiliary contacts</b>	3
<b>number of NO contacts for auxiliary contacts</b>	3
<b>Connections/ Terminals</b>	
type of electrical connection of modules and accessories	Screw-type terminal
<b>type of electrical connection on enclosure</b>	Cable routing above and below, both 1 x M20
<b>tightening torque of the screws in the bracket</b>	1 ... 1.2 N·m

tightening torque of fixing screws in the enclosure cover	1.5 ... 1.7 N·m
tightening torque with screw-type terminals	0.8 ... 0.9 N·m
<b>Ambient conditions</b>	
<b>ambient temperature</b>	
• during operation	-25 ... +70 °C
• during storage	-40 ... +80 °C
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 ... 95%, no condensation in operation permitted for all devices behind front panel)
<b>Installation/ mounting/ dimensions</b>	
fastening method of modules and accessories	Floor mounting
height	154 mm
width	85 mm
depth	75 mm
shape of the installation opening	round
<b>Accessories</b>	
number of labels	3
color of the label	A = black / B = black / C = black
number of inscription plates	3
<b>Certificates/ approvals</b>	
<b>General Product Approval</b>	



[Confirmation](#)



<b>Declaration of Conformity</b>	<b>Test Certificates</b>	<b>Marine / Shipping</b>
----------------------------------	--------------------------	--------------------------



[Type Test Certificates/Test Report](#)



<b>Marine / Shipping</b>	<b>other</b>
--------------------------	--------------



[Confirmation](#)

[Environmental Confirmations](#)

**Further information**

Information- and Downloadcenter (Catalogs, Brochures,...)

<https://www.siemens.com/ic10>

Industry Mall (Online ordering system)

<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1803-0AS00-2AB1>

Cax online generator

<http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SU1803-0AS00-2AB1>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<https://support.industry.siemens.com/cs/ww/en/ps/3SU1803-0AS00-2AB1>

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

[http://www.automation.siemens.com/bilddb/cax\\_de.aspx?mlfb=3SU1803-0AS00-2AB1&lang=en](http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SU1803-0AS00-2AB1&lang=en)

last modified:

1/26/2022